

RIBM2402B

LED ON = RELAY ACTIVATED

Bulletin B539 • 393021D

Functional Devices, Inc.

310 South Union Street

Russiaville, IN 46979

Phone: (765)883-5538

Fax: (765)883-7505

COIL



Comm



24Vac/dc



208-277Vac

SIGNALING



LISTED

13CY

15M6

TYPE F, G, EM

For use with

Smoke Control System

General Signaling Equip. NM

www.functionaldevices.com

CONTACT RATINGS

20A Res. @ 277 Vac

1 HP @ 120 Vac

2 HP @ 277 Vac

20A Ballast @ 277 Vac (N/O)

10A Ballast @ 277 Vac (N/C)

16A Elect. Ball. @ 277 Vac (N/O)

10A Tung. @ 120 Vac (N/O)

770 VA Pilot @ 120 Vac

1110 VA Pilot @ 277 Vac

COIL RATINGS

47mA @ 30Vdc max.

83mA @ 24Vac max.

47mA @ 120Vac max.

FOR SUPPLY CONNECTIONS USE #12 AWG OR LARGER WIRES RATED AT LEAST 75°C (167°F).

CONTACTS

Comm



N/O



N/C

